

**To:** Bair, Rita[bair.rita@epa.gov]  
**Cc:** Henry, Timothy[henry.timothy@epa.gov]; Poy, Thomas[poy.thomas@epa.gov]  
**From:** Hyde, Tinka  
**Sent:** Mon 8/1/2016 8:56:28 PM  
**Subject:** RE: East Chicago Drinking Water System

Thanks much Rita!

**From:** Bair, Rita  
**Sent:** Monday, August 01, 2016 3:49 PM  
**To:** Hyde, Tinka <hyde.tinka@epa.gov>  
**Cc:** Henry, Timothy <henry.timothy@epa.gov>; Poy, Thomas <poy.thomas@epa.gov>  
**Subject:** East Chicago Drinking Water System

Here are some factoids about East Chicago's Water System that you asked for.

- The East Chicago Water Works (IN5245012) is a surface water system utilizing Lake Michigan water that serves 29,500 people.
- The last violation they had was a DBP M&R violation in the first quarter of CY2016.
- In 2015 they had a treatment technique violation for the month of June for an IESWTR filter violation. The violation was returned to compliance on 8/4/15. No other violations have occurred since 1994.
- The last lead and copper sampling was done for the 2012-2014 time period. There have been no ALEs. A copy of the lead results dating back to 1995 are below.

Let me know if you need anything else.

Monitoring Period	Monitoring Period	Number of Samples	Measure (mg/l)	Water System Facility	Date Summary Received	Analyte
Begin Date	End Date			State	Asgn ID No.	

01-01-2012	12-31-2014	30	.0078	DS001	08-26-2014	Lead
01-01-2011	12-31-2013	30	.0036	DS001	08-02-2011	Lead
01-01-2008	12-31-2010	30	.0077	DS001		Lead
01-01-2005	12-31-2007	30	.005	DS001		Lead
01-01-2002	12-31-2004	30	.0037	DS001		Lead
01-01-1999	12-31-2001	30	.0005	DS001		Lead
01-01-1996	12-31-1996	30	.012	DS001		Lead
01-01-1995	12-31-1995	30	.012	DS001		Lead